



Certificate / Certificat Zertifikat / 合格証

MIT 1211024 C003

exida hereby confirms that the:

Globe Control Valves

**Mitech Control Valve (Pty) Ltd
Johannesburg, Gauteng - RSA**

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Globe Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer may use the mark:



Revision 3.0 June 26, 2024
Surveillance Audit Due
July 1, 2027



Evaluating Assessor

Certifying Assessor

MIT 1211024 C003

Systematic Capability: SC 3 (SIL 3 Capable)**Random Capability: Type A, Route 2_H Device****PFH/PFD_{avg} and Architecture Constraints
must be verified for each application****Systematic Capability :**

These product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Application/Device/Configuration	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DD}	#
Full Stroke, Clean Service	0	0	0	521	746
Tight Shut-Off, Clean Service	0	0	0	1256	11
Open on Trip, Clean Service	0	168	0	353	746
Full Stroke, Severe Service	0	0	0	943	1472
Tight Shut-Off, Severe Service	0	0	0	2405	11
Open on Trip, Severe Service	0	329	0	614	1472

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: MIT 12-11-024 R004 V1 R4 (or later)

Safety Manual: SHEQSIL-1 Rev 2

Globe Control Valves



80 N Main St
Sellersville, PA 18960